



# Central City Water Works Water Quality Report for year 2018

PO Box 430  
Central City, KY 42330  
PWSID#0890071

Meetings: Water Office  
Meeting Dates: 2<sup>nd</sup> Monday of each Month  
Meeting Time: 4:00 PM

Manager:  
David Rhoades  
Phone: (270) 754-3066

CCR Contact:  
Ronald Mobley  
Phone: (270) 754-5160

This report is designed to inform the public about the quality of water and services provided on a daily basis. Our commitment is to provide our customers with a safe, clean, and reliable supply of drinking water. We want to assure that we will continue to monitor, improve, and protect the water system and deliver a high quality product. Water is the most indispensable product in every home and we ask everyone to be conservative and help us in our efforts to protect the water source and the water system.

Central City treats surface water from the Green River. The source water assessment for the system is contained in the Muhlenberg County Water Supply Plan prepared by the Pennyrite Area Development District. The area upstream contains residential, agricultural, and mining activities. The source water assessment identified 246 potential sources of contamination with 208 of those sites identified as moderate risk. However, several sites were identified as high risk. There are twenty-five oil/gas wells and ten landfills which present the possibility of contamination from leaching, siltation, and illegal dumping. There are ten underground/aboveground storage tank facilities and three auto repair facilities which have the potential for contamination due to leaking petroleum containers and spills. Other potential concerns within the watershed are roads, bridges and highways which pose a risk due to the possibility of hazardous materials entering the water supply from traffic accidents, spills, and illegal dumping. Copies of the plan are available at the Central City Water Department.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environment Protection Agency's Safe Drinking Water hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharge, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production or from gas stations, stormwater runoff or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities).

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

*Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water hotline (800-426-4791).*

We received a public notice violation on March 6, 2018 Violation Number 2018-9951217. The violation type 75 public notice rule linked to violation. The public notice was distributed in the local newspaper, with our 2017 CCR and this does not meet the requirements for directly delivering of a public notice. The original Violation 2016-9951216 was issued due to Failure to have a Monitoring Plan in place (LT2) for compliance period of 07/02/16. We are working closely with the Division of Water to ensure that regulations regarding Public Notices are followed in the future.

Some or all of these definitions maybe found in this report:

**Maximum Contaminant Level (MCL)** – the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** – the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** – the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** – the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Below Detection Levels (BDL)** – laboratory analysis indicates that the contaminant is not present.

**Not Applicable (N/A)** - does not apply.

**Parts per billion (ppb)** – or milligrams per liter, (mg/l). One part per billion corresponds to one minute in two years or a single penny in \$10,000.

**Parts per trillion (ppt)** – one part per trillion corresponds to one minute in 2,000,000 years or one penny in \$10,000,000,000.

**Picocuries per liter (pCi/L)** – a measure of the radioactivity in water.

**Millirems per year (mrem/yr)** – measure of radiation absorbed by the body.

**Million Fibers per Liter (MFL)** – a measure of the presence of asbestos fibers that are longer than 10 micrometers.

**Nephelometric Turbidity Unit (NTU)** – a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

**Variances & Exemptions (V&E)** – State of EPA permission not to meet an MCL or a treatment technique under certain conditions.

**Action Level (AL)** – the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

**Treatment Technique (TT)** – a required process intended to reduce the level of a contaminant in drinking water.

## Information About Lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from material and components associated with service lines and home plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at: <http://www.epa.gov/safewater/lead>

Spanish (Española) Este informe contiene información muy importante sobre la Calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old.

	Allowable Levels	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity
Turbidity (NTU) TT * Representative samples of filtered water	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples	0.08	100	No	Soil runoff

**Regulated Contaminant Test Results**

Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
----------------------------	-----	------	--------------	--------------------	----------------	-----------	--------------------------------

**Inorganic Contaminants**

Barium [1010] (ppm)	2	2	0.026	0.026 to 0.026	Oct-18	No	Drilling wastes; metal refineries; erosion of natural deposits
Copper [1022] (ppm) sites exceeding action level 0	AL = 1.3	1.3	0.0072 (90 <sup>th</sup> percentile)	0 to 0.0287	Jun-16	No	Corrosion of household plumbing systems
Fluoride [1025] (ppm)	4	4	0.70	0.7 to 0.7	Oct-18	No	Water additive which promotes strong teeth
Nitrate [1040] (ppm)	10	10	1.2	1.2 to 1.2	Jan-18	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits

**Disinfectants/Disinfection Byproducts and Precursors**

Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	1.73 (lowest average)	1.76 to 2.30 (monthly ratios)	2018	No	Naturally present in environment.
--	-----	-----	-----------------------	-------------------------------	------	----	-----------------------------------

\*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.

Chlorine (ppm)	MRDL = 4	MRDLG = 4	1.60 (highest average)	0.31 to 2.12	2018	No	Water additive used to control microbes.
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	48 (high site average)	17 to 52 (range of individual sites)	2018	No	Byproduct of drinking water disinfection.
THM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	43 (high site average)	12 to 55 (range of individual sites)	2018	No	Byproduct of drinking water disinfection.

**Other Contaminants**

Cryptosporidium [oocysts/L]	0	TT (99% removal)	2 (positive samples)	8 (no. of samples)	2018	See note below	Human and animal fecal waste
-----------------------------	---	------------------	----------------------	--------------------	------	----------------	------------------------------

Cryptosporidium. We are required to monitor the source of your drinking water for Cryptosporidium in order to determine whether treatment at the water treatment plant is sufficient to adequately remove Cryptosporidium from your drinking water.

Cryptosporidium is a microbial pathogen found in surface water. Cryptosporidium was detected in 2 sample of 8 collected from the raw water source for our water system. It was not detected in the finished water. Current test methods do not enable us to determine if the organisms are dead or if they are capable of causing disease. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Cryptosporidium must be ingested to cause disease and it may be spread through means other than drinking water.

	Average	Range of Detection
Fluoride (added for dental health)	0.8	0.58 to 1
Sodium (EPA guidance level = 20 mg/L)	15.8	15.8 to 15.8

Secondary contaminants do not have a direct impact on the health of consumers. They are being included to provide additional information about the quality of the water.

Secondary Contaminant	Maximum Allowable Level	Report Level	Range of Detection	Date of Sample
Aluminum	0.05 to 0.2 mg/l	0.16	0.16 to 0.16	Aug-18
Chloride	250 mg/l	24.7	24.7 to 24.7	Aug-18
Corrosivity	Noncorrosive	0.44	0.44 to 0.44	Aug-18
Fluoride	2.0 mg/l	0.7	0.7 to 0.7	Aug-18
pH	6.5 to 8.5	8.13	8.13 to 8.13	Aug-18
Sulfate	250 mg/l	102	102 to 102	Aug-18
Total Dissolved Solids	500 mg/l	361	361 to 361	Aug-18

This report will not be sent to individual customers. It will be available at City Hall.